


**NOTES:**

- 1) BACKFLOW UNITS SHALL BE ON THE "APPROVED BACKFLOW PREVENTION DEVICES" LIST BY THE HEALTH SERVICES AGENCY A DEPARTMENT OF THE PUBLIC HEALTH AND ENVIRONMENTAL PROTECTION DIVISION OF THE COUNTY OF SANTA CLARA
- 2) SEAL ALL THREADED JOINTS 2" & SMALLER WITH PIPETHREAD SEALANT. FOR LARGER PIPES USE PIPETHREAD SEALANT & TEFLON TAPE
- 3) ALL BURIED GALVANIZED PIPES AND PIPE FITTINGS SHALL BE WRAPPED WITH 8-MIL POLYETHYLENE AND SECURED WITH 10-MIL POLY TAPE

Approved:  1/4/10  
 City Engineer Date



| REVISION    |      |
|-------------|------|
| Description | Date |
|             |      |
|             |      |
|             |      |
|             |      |

|                                   |             |
|-----------------------------------|-------------|
| <b>ENGINEERING DIVISION</b>       |             |
| <b>BACKFLOW PREVENTION DEVICE</b> | <b>LI-2</b> |